

CERTIFICATE OF CONFORMANCE TO ASTM F 3010-13

Koster American Corporation certifies that the following products meet the requirements of ASTM F3010-13 *Standard Practice for Two-Component Resin Based Membrane-Forming Moisture Mitigation Systems for Use Under Resilient Floor Coverings* when installed according to the manufacturer's instructions on properly prepared concrete.

	Two-component resin based product	Water Vapor Permeance^{1,2} ASTM E96 water method 73°F/50%RH grains•hr⁻¹•ft⁻²•in. Hg⁻¹
Criteria:	Yes	Not exceed 0.1
Product		
KOSTER VAP I® 2000	Yes	0.091
KOSTER VAP I® 2000 Zero VOC	Yes	0.056
KOSTER VAP I® 2000 FS	Yes	0.047
KOSTER VAP I® 2000 UFS	Yes	0.060

Notes

1. Products applied at 100 ft²/gal to ICRI CSP3 abrasively blasted concrete.
2. Net permeance of coating corrected for uncoated substrate concrete.



Howard Kanare
Technical Director

e-mail: howard@kosterusa.com

Phone: (757) 425-1206

Fax: (757) 425-9951